

Quality Certificate

Hawa Sliding Solutions AG hereby certifies that the sliding door fittings of the product line **Hawa Junior 120** comply with the requirements of **EN 1527**.

Test information

Classification:	EN 1527 : 2013
Door weight:	120 kg
Durability:	100'000 cycles
Overload test:	EN 15706 : 2009 - Level 3
Functional test:	EN 15706 : 2009 - Level 3

Additional information

Ease of installation:	Requirements complied
Tested by:	Laboratory, TÜV Rheinland LGA Products GmbH, Nürnberg, Germany, test certificate no. LI 60091730 0001
Quality assurance:	External and internal monitoring in accordance with SN EN ISO 9001 : 2015

Mettmenstetten, January 1st 2021



Ezequiel Di Claudio
Chief Executive Officer (CEO)



Peter Möller
Chief Executive Officer (CEO)

LGA - Qualitäts - Zertifikat

LGA-Quality-Certificate



Genehmigungsinhaber
License Holder

Hawa AG
Untere Fischbachstr. 4
8932 Mettmenstetten
Schweiz

Zertifiziertes Produkt (umseitig näher bezeichnet)
Certified Product (specified overleaf)

Sliding door fitting HAWA-Junior 120/A, -B, -G, -GP

Prüfzeichen Test Mark



LGA-Qualitäts-Zertifikats-Nr.:
LGA-Quality-Certificate No.

LI 60091730 0001

Untersuchungsbericht-Nr.:
Test Report No.

21217166 001

Geprüft nach Tested acc. to

DIN EN 1527/03.13

DIN EN 15706/08.09

2 PFG Q2274/05.13

Datum Date 25.07.2014

Zertifizierungsstelle Certification Body

K.-H. Heider



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.

The certificate is based on our Testing and Certification Regulations.

Das Produkt entspricht o.g. Anforderungen, die Herstellung wird überwacht.

The product fulfills above mentioned requirements, the production is subject to surveillance.

Übersetzung/Translation

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Tel.: +49 221 806-1371 Fax: +49 221 806-3935 e-mail: cert-validity@de.tuv.com http://www.tuv.com/safety

Genehmigungsinhaber License Holder

Hawa AG
Untere Fischbachstr. 4
8932 Mettmenstetten
Schweiz

Fertigungsstätte Manufacturing Plant

Hawa AG
Untere Fischbachstr. 4
8932 Mettmenstetten
Schweiz

Ihr Zeichen Client Reference	Unser Zeichen Our Reference	Längstens gültig bis Latest expiration date (day/mo/yr)
-------------------------------------	------------------------------------	---

0010--21217166 001

Zertifiziertes Produkt (Geräteidentifikation) <i>Certified Product (Product Identification)</i>	Lizenzentgelte - Einheit <i>License Fee - Unit</i>
---	--

Fittings

Sliding door fitting HAWA-Junior 120/A, -B, -G, -GP

7

Strength, functionality,
and safety properties

Requirements acc. to 2 PfG-Q 2274,
DIN EN 15706 testing level 3 and
DIN EN 1527 fulfilled

Classification acc. to
DIN EN 1527

see Appendix

Loading capacity

120 kg

Durability

100.000 cycles

Quality assurance

External and Production quality
control

Replaces certificate No. LI 60036707 0001

7

Anlage / Appendix 1



Zertifikat / Certificate

Blatt / Page

LI 60091730

0001

Ihr Zeichen / Client Reference

Unser Zeichen / Our Reference

Ausstellungsdatum / Date of issue

0010—21217166_001

25.07.2014

Classification acc. to DIN EN 1527

- 6 3 - 1 0 - 1 3

Category of use (1st digit):

No grade identified for these products.

Durability (2nd digit):

- grade 1 = 5000 test cycles
- grade 2 = 10000 test cycles
- grade 3 = 25000 test cycles
- grade 4 = 50000 test cycles
- grade 5 = 75000 test cycles
- grade 6 = 100000 test cycles

Door mass (3rd digit):

- grade 1 = door up to 50 kg
- grade 2 = door from 51 kg to 100 kg
- grade 3 = door from 101 kg to 330 kg
- grade 4 = door over 330 kg

Fire resistance (4th digit):

No grade identified for these products.

Safety (5th digit):

All sliding design systems and sliding folding design systems conforming to this standard shall be classified as grade 1 for safety.

Corrosion resistance (6th digit):

Products are classified from 1 to 5 according to the six grades defined in EN 1670. Grade 0 is for products not tested.

Security (7th digit):

No grade identified for these products.

Category of door (8th digit):

- grade 1 = sliding door
- grade 2 = folding door (bi-fold type)
- grade 3 = multi-panel folding door

Initial friction maximum permitted value (9th digit):

Door mass	from 0 kg to 50 kg	from 51 kg to 100 kg	from 101 kg to 330 kg	Over 330 kg
Grade 1	50 N	80 N	100 N	5 % of the mass
Grade 2	40 N	60 N	5 % of the mass	4 % of the mass
Grade 3	30 N	40 N	4 % of the mass	3 % of the mass

K.-H. Heider

Übersetzung/Translation

